

Appendix 2

From: Environmental Health
Sent: 05 July 2017 15:31
To: Licensing
Subject: FW: RE: New premise licence application - 370 Cheriton Road
Attachments: image001.jpg; image002.jpg

FYI

From: Tse, Wai [<mailto:Wai.Tse@shepway.gov.uk>]
Sent: 21 June 2017 09:58
Subject: RE: New premise licence application - 370 Cheriton Road

Hi Arthur,

RE: New premise licence application - 370 Cheriton Road

Environmental Health would object to this application due to the proposal of a stage with live performances going up to 22:30hrs. Even if it is unamplified music, it is highly likely to still cause a noise nuisance to occupiers of the residential property above.

I would only permit ancillary (background) music only. No live entertainment including DJ music.

The property must also achieve a $55\text{dB } D_{nT,W} + C_{tr}$ value of insulation between the residential and commercial property. An acoustic report should be carried out by a competent person, in this case a competent person must be registered with the institute of acoustics. They must demonstrate or advise the level of insulation needed to achieve the set value within this property.

Reason: The council needs to be satisfied that the level of sound insulation provided will be sufficient to deal with the level and character of the sound sources below, and that this will in turn result in acceptable internal noise levels above i.e BS2833:2014 levels and not cause unreasonable noise nuisance to nearby residential premises.

Kind regards

Mr. Wai Tse
Environmental Protection Officer
Environmental Health
Shepway District Council
Civic Centre, Castle Hill Avenue, Folkestone, Kent, CT20 2QY
Tel: 01303 853550
Email: wai.tse@shepway.gov.uk
Web: www.shepway.gov.uk
Follow us on Twitter and Facebook